



REF - SFA 7122

Date: 21/08/2024

TO WHOM IT MAY CONCERN

Certified that the triple Storey Building of **Sardarni Joginder Kaur Hayer Memorial Education Trust Shahabad(M.)** Situated at Ladwa Road, Himgiri Colony in Khewat No. 25/1, 16/1, Shahabad Markanda, Dist. Kurukshetra constructed as per Bye-Laws & detailed below.

The building has been amply provided with drinking water, toilet & electricity.

The specification are as below :

Sr.No.	ITEMS	SPECIFICATION
1	Foundation	C.Concrete 1:8:16
2	Walls	First class brick work laid in cement sand mortar (1:7)
3	DPC	40 mm thk. C.concrete 1:2:4 with two coats of hot bitumen
4	Roof	115 mm thk. R.C.C. Slab 1:2:4 as per IS 456 with two coats of hot bitumen laid
5	Steel Work	Cold twisted mild steel deformed bars as per I.S. 229
6	Floor	There is C.C flooring in the rooms & Verandah
7	Doors & Windows	Chowkhats of Z-Section/ M.S angle iron & shutter of the door & window paneled & enameled painted
8	Internal Finish	Cement plastering with cement mortar (1:5) finished with two coats of white wash
9	External Finish	Cement plastering with cement mortar (1:5) finished with two coats of white wash
10	Ventilation	Full size window have been provided along with door & are sufficient for ventilation

I done verify on 21/08/2024 at Shahabad Markanda.

As Parveen Chopra
SAAKAAR FOUNDATION
CA 35/18088
SCO 53, 55, IIIrd FLOOR,
SEC-17-D, CHANDIGARH
Managing Director
SAAKAAR FOUNDATION


SAAKAAR FOUNDATION



▪ ARCHITECTS ▪ ENGINEERS ▪ PLANNERS PHONE : 0172-2722466, 3043466
S.C.O. 53-55, 3RD FLOOR, NEAR G.P.O. FAX : 0172-2721145, 2711931
SECTOR 17-D, CHANDIGARH-160017 (INDIA) E-MAIL : saakaarfoundation@yahoo.co.in

Certified that the structural parts of the entire building of **Sardarni Joginder Kaur Hayer Memorial Education Trust Shahabad (M) Distt. Kurukshetra** have been designed by me on the basis of calculation and considered safe in accordance with the permissible stresses and slenderness ratio. Building is designed as per N.B.C and earthquake proof. This certificate is valid from the date of issue to till 20th August 2027.

In my view the building is very good fit & safe to serve as an educational institute building.


SAAKAAR FOUNDATION
CA 95/18088
SCO 53, 55, IIIrd FLOOR,
SEC-17-D, CHANDIGARH

Ar. Parveen Chopra

Managing Director

SAAKAAR FOUNDATION