



ARCHITECTS = ENGINEERS = PLANNERS
 S.C.O. 53-55, 3RD FLOOR, NEAR G.P.O. FAX : 0172-27221145, 2711931
 SECTOR 17-D, CHANDIGARH-160017 (INDIA)
 E-MAIL : saakaarfoundation@yahoo.co.in

REF - SFA 7121 Date: 21/08/2023

## **TO WHOM IT MAY CONCERN**

Certified that the triple Storey Building of <u>Sardarni Joginder Kaur Hayer</u> <u>Memorial Education Trust Shahabad(M.)</u> Situated at Ladwa Road, Himgiri Colony in Khewat No. 25/1, 16/1, Shahabad Markanda, Dist. Kurukshetra constructed as per Bye-Laws & detailed below.

The building has been amply provided with drinking water, toilet & electricity.

The specification are as below:

	ITEMS	SPECIFICATION
4		
1	Foundation	C.Concrete 1:8:16
2	Walls	First class brick work laid in cement sand
		mortar (1:7)
3	DPC	40 mm thk. C.concrete 1:2:4 with two coats
		of hot bitumen
4	Roof	115 mm thk. R.C.C. Slab 1:2:4 as per IS
		456 with two coats of hot bitumen laid
5	Steel Work	Cold twisted mild steel deformed bars as
		per I.S. 229
6	Floor	There is C.C flooring in the rooms &
		Verandah
7	Doors & Windows	Chowkhats of Z-Section/ M.S angle iron &
		shutter of the door & window paneled &
		enameled painted
8	Internal Finish	Cement plastering with cement mortar (1:5)
		finished with two coats of white wash
9	External Finish	Cement plastering with cement mortar (1:5)
		finished with two coats of white wash
10	Ventilation	Full size window have been provided along
		with door & are sufficient for ventilation





ARCHITECTS = ENGINEERS = PLANNERS
 PHONE : 0172-2722466, 3043466
 S.C.O. 53-55, 3RD FLOOR, NEAR G.P.O. FAX : 0172-2721145, 2711931
 SECTOR 17-D, CHANDIGARH-160017 (INDIA)
 E-MAIL : saakaarfoundation@yahoo.co.in

## Certified that the structural parts of the entire building of <u>Sardarni Joginder</u> <u>Kaur Hayer Memorial Education Trust Shahabad(M.)</u> Distt. KKR

have been designed by me on the basis of calculation and considered safe in accordance with the permissible stresses and slenderness ratio. Building is designed as per N.B.C and earthquake proof. This certificate is valid from the date of issue to till Aug. 20<sup>th</sup> 2024.

In my view the building is very good fit & safe to serve as an educational institute building.

SAAKAAR FOUNDATION CA M95/18088 SCO 58, 55, IIIrd FLOOR, SEC-17-D. CHANDIGARH